

**Office of the Sr. M & MO, I/C Digboi Civil Hospital.**  
**Health & Family Welfare (A) Deptt. Govt. of Assam.**

No. DIGBOI CHC/R2-23/008

Dated Digboi, the 26/4/2022

This is to certify that an inspection was made on 26/4/2022 at Delhi Public School, Digboi as per request from the Principal, DPS, Digboi vide letter No. DPS / Dig / adm /2022/9142, dtd. 23<sup>rd</sup> April, 2022, regarding the sanitary condition and Drinking Water facility in the school.

**Findings of the inspection are as follows :**

**1) Sanitary Condition :**

(a) Septic Tank and Latrines : School building is provided with 5 septic tanks with installed capacity of 642 users against total students and staffs of 1250 (approx). Separate toilets for boys & girls are there. Total no. of toilet rooms are 8 with 12 Latrines ( with flush, tap with 24 hours running water and collecting pot) and 16 urinals (For boys 8 and for girls 8). All the sanitary rooms & toilets are regularly cleaned ( with 24 hours running water, commode / squatting plate regularly cleaned). There are 24 wash basins ( with tap and soap provided ) separate for boys and girls and 8 workers are regularly deployed for continuous cleaning of toilet rooms during school hours.

(b) Drainage system : 27 acres of land is drained by several cemented nullahs finally flowing into a running drain. There is no water logging. Drainage system is clean.

(c) Garbage Disposal : There are several Dustbins in the class rooms and around the school campus, which are clean, solid waste is burnt down and biological wastes are put in a pit well away from the school campus and buried regularly. 15 workers are deployed for Campus cleaning.

**2) Drinking water facility :**

Approximately 400 litres of Pre-filtered water is provided by IOCL to a overhead tank for daily use. Drinking water is additionally filtered in water filters, placed in different locations. The water provided by IOCL is regularly checked for Physical, Chemical and Bacteriological qualities by IOCL authorities. The school has installed 8 Aquaguard for purified water for the students.

Based on above findings of actual and physical verification, it is certified that, the Delhi Public School, situated at IOCL Township, Po. Digboi, Dist: Tinsukia, Assam, conforms to the standard of hygiene in respect of sanitary condition and Drinking water facility on the date of inspection.



M  
26/4/22  
Sr. M & HO, I/C  
Digboi Civil Hospital, Digboi.  
I/C Medical & Health Officer-1  
Digboi CHC